



NOTES:

1. CLEAN TANK COMPLETELY AFTER WELDING.
2. INSPECT TANK FOR UNDERCUT & CONCAVE WELDS BEFORE SECOND TEST.
3. SECOND TEST TANK AFTER SILLS ARE WELDED.

PRODUCT CODE: SW300FSK38D		DESCRIPTION: 300 GALLON NON-UL SKID TANK Ø38" X 5'-0" LONG 12 GAUGE			STEEL TANK & FABRICATING CORP. COLUMBIA CITY, IN 46725 <small>800-852-9102 / 260-248-8971 / FAX 260-248-8973</small>			
FOR: STOCK	CUSTOMER APPROVAL: <input type="checkbox"/> MAKE NOTED CHANGES AND RE-SUBMIT <input type="checkbox"/> APPROVED WITH CHANGES NOTED <input type="checkbox"/> APPROVED AS DRAWN	QUANTITY: 6	CAPACITY: 300 GAL	APP. WEIGHT: 328 lbmass				
PAIN: PRIMER/TOPCOAT	SIGNATURE: _____	DIAMETER: 38"	LENGTH: 5'	SHELL: 12GA	SCALE: 1 / 12	FILE NAME:	SHEET: 1 OF 1	

A

A

B

B

4

3

2

1

4

3

2

1